

MINUTES OF THE PRE-BID MEETING HELD ON 28.11.2024 AT THE AUDITORIUM OF ENGINEERING FUNCTION.

“SUPPLY INSTALLATION, TESTING, COMMISSIONING AND MAINTENANCE OF GRID-TIED ROOF MOUNTED SOLAR PV GENERATION SYSTEM AT MAIN GARAGE HANGER (187k Wp) & NEW BUILDING (100k Wp) AT CPSTL, OIL INSTALLATION KOLONNAWA.”

At the beginning of the meeting the Chairman of TEC introduced the TEC members and suggested the participants to introduce themselves.

The Chairman of TEC then briefed about the contract and informed that a site visit would be possible after submitting their queries. Considering the time constraints, the Chairman of the TEC advised the participants to send their queries via email before 02.12.2024. The queries raised during the pre-bid meeting, along with those submitted by email, and the answers from CPSTL are summarized in the table below.

Queries raised by the bidders

	Queries/Clarifications	CPSTL Answer
01.	e-bills (month of November & December) for both garage hanger and new building.	Attached.
02.	CAD drawing files	CAD drawing files are not provided by CPSTL due to security concerns.
03.	In reference to Specification 6.4.1.2 (Page 42, Point f), the requirement mentions the use of multiple 3-phase inverters for the system. However, during the pre-bid meeting, it was observed that the proposed inverter room for the 100kW new building appears to be too small to accommodate two inverters as per the current specification. Given this constraint, we would like to seek clarification on whether it would be acceptable to use a single inverter for this case, provided it meets all other technical and operational requirements outlined in the specification.	Bidders may propose a single inverter for this case
04.	Minimum module rating has been mentioned in the range of 570Wp to 595Wp. Is that okay if we use 605 Wp modules	The rated maximum power (Pmax) range shall be from 570Wp to 605Wp. Bidders are permitted to propose only models approved by the Sri Lanka Sustainable Energy Authority and accepted by the CEB. Relevant documents must be submitted along with the bid